

# **Retirement of Nuclear and Coal Fired Plants in the Western Japan Grid: Focusing on Supply-Demand Power Balance**

Asami TAKEHAMA (Ritsumeikan University),

Manabu UTAGAWA (AIST)

REFORM Group Meeting 2018


28th Aug 2018

Schloss Leopoldskron in Salzburg, Austria



**Currently**, Generation Companies are still Transmission System Operators.

Transmission Grids will be separated from Generation companies in **2020**.



# Backgrounds: Japan's grid operations, the current rules 1

- 9 Transmission System Operators (TSO) are 9 Generation Companies.
- Unbundling of Generation and Transmission will be in 2020.
- TSOs are **not obliged to expand Grid Capacity** for accommodating RES power.
- Nuclear power has the **first priority** to be fed-into the grid.
- Generation companies are only **obliged to reduce Output levels of Fossil Thermal plants from the Current Capacity levels** for accommodating RES.
- Japan's FIT law does **not regulate the reduction of capacity of thermal power** in a time of power oversupply.
- **PV and Wind power has a 'limited' priority to access to the zone grids.**

## ■ Japan's grid operations of Inter-Regional Lines, the current rules 2

- Nuclear power has the first priority to be fed-in to Inter-Regional lines.
- A large capacity of Inter-Regional Lines have been reserved by large-scale of Nuclear . 'First come, First serve' rule.
- Interzone tie-lines are operated according to 'Scheduled Power Flow' .
- >>> PV and Wind power has difficulties to be transmitted to Inter-Regional Lines.
- No Control Reserve is activated through Inter-Regional lines beyond the zone.
  - >>> There is **no Grid Control Cooperation** in Japan
- Power Supply-Demand is balanced in Each grid zone.

# ■ Aim of the study

■ Analyzing the impacts of PV and Wind power on **Supply-Demand Balance** in the Western Japan Grid in 2030.

■ UC-ELD model:

We developed a simplified **Unit Commitment and Economic Load Dispatching model** for thermal power units (by Matlab optimization tool box).

■ With the conditions of

- Zero Nuclear power
- Reduction of Coal power capacity
- PV and Wind power is transmitted to Inter-Regional Lines

## ■ Unit Commitment- Economic Load Dispatch model

Conventional Generator units are classified into **22 Subgroups**  
**Subgroup**

Coal 1,2,3, Oil 1, 2, 3. LNG Thermal 1, 2, 3  
Gas-CC 1, 2, 3. Independent Producers 1, 2, 3  
Inter-Regional Transmission,  
Nuclear, Pumped Storage, Reservoir (Hydro)


### **Priority Feed-in power**

PV, Wind, Biomass, Geothermal, Hydro (Run of River)

■ **Objective Function** : Minimizing **hourly Fuel Cost** [JPY/h]

### ■ **Endogenous Variables**

**Hourly power output** of generator Subgroup  $k$  [MW]  
to estimates Hourly Supply-Demand Balance in **May, August**



Pumped Storage
  Inter-Regional Lines
  Fossil

Hydro
  Wind
  Solar PV

## Technical limitations of fossil fired power plants in supply-demand balance

- ① Fossil power must satisfy residual load  
Residual load = Demand - RES
- ② Fossil power plants have power output minimum, if continuous operation
- ③ Fossil fired plants has speed limits for **ramp-up** of power output per minute.
- ④ Fossil fired plants has speed limits for **ramp-down** of power output per minute.

## ■ Constraints for UC-ELD Model

### ➤ **Minimum Output Limit:**

Coal plants: **15%** - 30% of capacity,

LNG Thermal, Gas-CC: 20% -30% of capacity

### ➤ **PV and wind is transmitted to Inter-Regional lines** < **80%\* Operational Capacity** of Inter-Regional Lines

### ➤ **LFC Control Reserve (CR)**

CR > 3% \* Demand at every hour

CR<sub>posi</sub> , CR<sub>nega</sub> > 5% \* Capacity of Subgroup k

Coal-fired units are not used for CR

CR compensates for 1-hour ahead PV forecast errors.

(max PV forecast error is 12% p.u)



## ■ High Case Assumptions for 2030

- Capacity of Coal power is reduced as much as possible with daily shut-downs
- **Zero nuclear is operated.**
- Demand is decreased -10%
- **HP:** Heat Pumps operation in daytime (household sector).
- **EV:** 20% of passenger vehicle charging in daytime
- **LFC Control Reserve** is activated beyond the control zone
- PV and wind power is transmitted to Inter-Regional Lines with a priority

## High case in Kyushu zone

[ MW], Base year= 2016


Kyushu	Base	High
PV Capacity	6,860	<b>18,200</b>
Wind Capacity	490	<b>4,700</b>
Nuclear Power	1,780	<b>0</b>
Inter-Regional Transmission Capacity	2,690	2,690
Inter-Regional Transmission from PV, Wind	No	<b>Yes</b>
Control Reserve through Inter-Regional Lines	No	<b>Yes</b>
Heat Pump	0	<b>810 MW *4 h * 2 sets</b>
Electric Vehicles	0	<b>700 MW* 8 h</b>
Pumped Storage Hydro Power	Pump-Up in Night, Daytime Generation	<b>PV Pump-Up, Evening Generation</b>
Pumped Storage Capacity	2,300	2,300
Demand (max)	15,500	<b>- 10%</b>
Demand (min)	6,400	<b>9 - 10%</b>

## 2030 targets of Renewable energies


	Demand in 2016 [MW]		2030 Targets [MW]			
	Max	Min	PV	Wind	Heat Pump	EV
Chubu	25,000	9,000	17,400	10,400	1,350 MW*4h*2	1,120 MW*8h
Kansai	27,000	10,000	13,900	3,400	1,780 MW*4h*2	890 MW*8h
Chugoku	11,000	5,000	8,000	3,200	840 MW*4h*2	460 MW*8h
Shikoku	5,000	2,000	5,000	2,600	600 MW*4h*2	240 MW*8h
Kyushu	16,000	6,000	18,200	4,700	810 MW*4h*2	780 MW*8h

## ■ Assumptions for 2030 High Case :

- Pumped Storage: Pumping in daytime, Generating in evening  
**(PV Pump-UP)**
- **Heat Pump** loading in daytime
- **EV** charging in daytime



# Western Japan Grid and Inter-Regional Transmission Linkages



Kansai and Chubu zones are calculated as an integrated single zone

## ■ High Case Assumptions


- Renewable power transmission to Inter-Regional Lines up to **80%\* operational capacity** with a priority
- **LFC Control Reserve** is activated through inter-regional lines

## ● Simulation results in Kyushu zone, High case in May

25% of PV power is absorbed by pumped storage,

27% of PV power is transmitted to Chugoku zone [% of MW] .


**Flexible grid operations** (Pumped Strg, Inter-regional lines, HP+ EV) can accommodate from 74% to 100% of VRE power (Variable Renewable Power).



## ■ Chugoku zone, High case in May

Max transmission to Kansai zone is 3.3 GW.

Max power oversupply occurs in the first week of May (national holidays).




# Kansai-Chubu zone, High case, in May

Power oversupply is on a limited scale relative to its demand size.


RES electricity share 21 % of MWh, 50% of Coal power capacity is in operation

CO2 emission 410g\_CO2 /kWh





Power Flow through Interzone Lines  
in the Western Grids (Results of the High case)



■ Inter-Regional Lines


Max transmission in May

■ Transmission of

Kyushu >> Chugoku reaches its **capacity limit** on many days of **May**

Takehama\_Utagawa\_REFORM Meeting, Salzburg, 2018


Western Grid (Kyushu, Chgoku, Shikoku, Kansai\_Chubu), TransPower to Kansai-Chubu zone in High scenario,, May





## ■ Results on Accommodation of VRE Power in Kyushu in May

- Flexible operation (Pumped Strg, Inter-Regional Transmission, HP and EV charging)
- **Flexible operations** accommodate the major portion of VRE power (75% to 100%)



■ **Large scales of oversupply** takes place on several days, mainly in the **first week** of May. Max oversupply: 4GW Kyushu, 3GW Chugoku, 0.8GW Shikoku.

■ Kyushu: Oversupply occurs on holidays & weekends

Takehama\_Utagawa\_REFORM Meeting, Salzburg, 2018

■ Kansai-Chubu : Oversupply is on a **limited scale** (relative to its demand size) <sup>17</sup>

## CO<sub>2</sub> emission and RE shares in High Case (in May)

Kyushu zone	Base (with nuclear)	Middle	High
Renewable Share in Generation [% of MWh]	14.2%	29.3%	39.3%
CO <sub>2</sub> emission [CO <sub>2</sub> _kg/kWh]	0.452	0.428	0.334
Fuel cost [USD/kWh]	0.066	0.075	0.076


Kyushu, Shikoku, Chugoku:  
RE shares are at 40%, 45%, 47% of total generation.

**CO<sub>2</sub> emission decreases from the base level.**

Chugoku zone	Base (with nuclear)	Middle	High
Renewable Share in Generation [% of MWh]	12.1%	33.1%	46.7%
CO <sub>2</sub> emission [CO <sub>2</sub> _kg/kWh]	0.490	0.392	0.307
Fuel cost [USD/kWh]	0.074	0.092	0.072

Shikoku  
Emission 0.44 >> 0.40  
RE Share 45 %

Supply and Load Rea, incl. ControlReserve, at power generation end, W1, hr 25-192  
 Kyusyu, High, PV18.2, Wd 4.7, Nucl 0 GW, HP 0.8, EV 0.7GW, Demand-10%  
 Kyushu, Aug



**Kyushu, Chugoku, Shikoku zone, in August (High load periods)**



**Risk of Supply Shortage in August is limited in Kyushu, Shikoku, Chubu zones,**

due to a sufficient PV power and energy saving measures.

RES electricity share 33% in Kyusyu.

39% in Chugoku [% of MWh]


Supply and Load Rea, incl. ControlReserve, at power generation end, W1, hr 25-192  
 Chugoku, High, PV 8, W 3.2, Nucl 0 GW, HP2.8GW, EV 0.45GW  
 Chugoku, Aug



Chugoku


## ■ Results in August (High load periods) in Kansai-Chubu zone

- The supply ability is very tight in August (zero Nuclear) . A small risk of **Supply Shortage in August** due to steep ramp-up of residual load in the evening ( 150MW in a few hours).
- Additional energy saving measures are required in August.
- Renewable share 15 % of MWh . Coal generation share 24 % of MWh.



## ■ Results on Control Reserve Activation

- Available capacity of **Negative Control Reserve** would be short in Kyushu, Shikoku, and Chugoku.
- However, an increase in **Negative Control Reserve** capacity could reduce grid capability to adapting to the **Down-Ramps** of LFC units.
- **Control Reserve activations through Inter-Regional Lines are required.**



**Thank you for your attention**

Asami TAKEHAMA (Ritsumeikan University),

Manabu UTAGAWA (AIST)

28 Aug 2018